

GOVERNMENT OF KERALA

Government Analysts' Laboratory Commissioner of Food Safety Department of Health and Family Welfare Thiruvananthapuram dtd. 27.04.2021 Ph: No. 0471-2472192

No.13034/2021-22

CERTIFICATE OF EXAMINATION

| Description of Sample: | Well water |
|------------------------|--|
| Sample details | The sample received in plastic can and sterile bottle |
| Source | Notre Dama School, Idichakkaplamoodu, Parassala.P.O., TVPM - 695 502 |
| Date of Receipt | 09.04.2021 |
| Date of Analysis | Started 13.04.2021 and completed on 27.04.2021 |
| Quantity of sample : | 2 L + 125 ml |
| Physical Appearance : | Clear, clolourless, odourless |
| Analytical results: | 4 |

| | | ***** | | |
|------------|--|-----------------------------|---------------|---------------------|
| Sl. No. | Quantity Characteristics | Name of method of test used | | Acceptable limit as |
| | (2) | (3), | (4) | per |
| (1) | | 1 | | IS No. 10500:2012 |
| | | | | (5) |
| 1. | P ^H | IS 3025 | 4.49 | 6.5 to 8.5 |
| 2. | Total Dissolved Solids | IS 3025 | 572.0 mg/l | 500.0 mg/l |
| 3. | Total Hardness (as CaCO ₃) | IS 3025 | 152.0 mg/l | 200.0 mg/l |
| 4. | Acidity | IS 3025 | 19.44 mg/l | |
| 5. | Iron (as Fe) | AOAC | 0.1 mg/l | 0.3 mg/l |
| 6. | Chloride (as Cl) | IS 3025 | 239.71 mg/l | 250.0 mg/l |
| 7. | Sulphates (as SO ₄) | АРНА | Nil | 200.0 mg/l |
| 8. | Residual Free Chlorine | IS 3025 | Nil | 0. 5 mg/l |
| 9., | Nitrate (as NO ₃) | Lab validated Method | 40.0 mg/l | 45.0 mg/l |
| 10. | Ammonia | IS 3025 | Nil | 0.5 mg/l |
| 11. | Turbidity | IS 3025 | 0.07 NTU | 5.0 NTU |
| 12. | Coliforms | IS 1622 : 1981, RA:2005 | <2 MPN/100 ml | <2 MPN/100 ml |
| 13. | E.Coli | IS 1622 : 1981, RA:2005 | Absent/100 ml | Absent /100 ml |
| | | | | ENID |

END

Remarks: വെള്ളത്തിന്റെ P^H കുറവാണ്. Total Dissolved Solids കൂടുതലാണ്. വെള്ളം വറ്റിച്ച് കിണർ വൃത്തിയാക്കുക. നാലായിരം ലിറ്റർ വെള്ളത്തിന് **250** ഗ്രാം കുമ്മായം പ്രയോഗിക്കുക.

. .. 1...

MANAGER NOTRE DAME SCHOOL IDICHAKKAPLAMOODU.

PARASSALA - P.O.- 695 502 TRIVANDRUM DIST.

PRINCIPAL NOTRE DAME SCHOOL IDICHAKKAPLAMOODU. PARASSALA - P.O TRIVANDRUM Food Analys Ge Tamuja

Seal

DEPARTMENT OF HEALTH SERVICES, KERALA PRIMARY HEALTH CENTRE .PARASUVAIKKAL GRAMA PANCHAYATH ,PARASSALA

SANITARY FITNESS CERTIFICATE

This is to certify that I have visited the NOTRE DAME School,Idichakkaplamoodu,Parassala P.O (Building No PP VII/201 &774) belongs to Neyyattinkara revenue district of Neyyattinkara Taluk of Trivandrum district on 17. 04.2021 and inspected the sanitary conditions provided at the School. During inspection I find the School and the surrounding were very conducive for the children and the Staff. The school was kept clean and tidy. The latrines and urinals provided at the school are adequate in number and are found very well maintained. There is sufficient amount of drinking water available at the compound and is found neatly maintained. In all respect the sanitary arrangements provided at the school were good.

So I certify that the Sanitary Conditions provided at the School are satisfactory and hence recommended NOTRE DAME School,Idichakkaplamoodu,Parassala P.O for permission and recognition for the year 2021-'22.



MANAGER NOTRE DAME SCHOOL IDICHAKKAPLAMOODU. PARASSALA - P.O.- 695 502 TRIVANDRUM DIST.

Health Inspector

PHC Parasuvaikkal

MEALTH INSPECTOR PHC Parasuvaiktal

Januga

PRINCIPAL NOTRE DAME SCHOOL IDICHAKKAPLAMOODU. PARASSALA - P.O. - 595 502 TRIVANDRUM DIST.